

Permit Case Summary

Case Number: [Search Help](#)

Case Number:SEP2004-00192	Case Status :Finaled	Date Received:8/10/2004				
Description: SEP78-217 (Abandoned) Now filed here. serves Sportsmans Club	Date Issued:9/23/2004					
Applicant: JEFFERSON COUNTY SPORTSMAN CLUB	Expiration Date:3/23/2005 12:00:00 AM					
Site Address:COUNTY LANDFILL RD	Case Finaled:3/6/2006					
Parcel No:001083012	Other Cases	Parcel Data	Map It	More Details	Parcels	Images

Case Actions

Below is a list of actions that have been taken by staff for this permit case. They are sorted based on the date they were added to the database with most recent actions at the top. A value in the "Date Completed" field indicates that the action has been completed.

Description:	SEPTIC PERMIT FINALED "F"
Date Completed:	3/6/2006
Disposition:	DONE
Description:	Issue permit (F)
Date Completed:	9/23/2004
Disposition:	DONE
Description:	Pending letter; add inf (F)
Date Completed:	9/23/2004
Disposition:	DONE
Description:	Septic Permit Application (F)

Date Completed:	8/11/2004
Disposition:	DONE
Description:	Print ESA Review Form-F
Date Completed:	8/11/2004
Disposition:	
Description:	Case Entered
Date Completed:	8/11/2004
Disposition:	
Description:	Stormwater Review-U
Date Completed:	9/8/2004
Disposition:	DONE
Description:	Env. Sensitive Area Review-U
Date Completed:	9/8/2004
Disposition:	DONE
Description:	Initial Site Inspection by HD
Date Completed:	9/2/2004
Disposition:	DONE
Description:	Pressure test required
Date Completed:	12/22/2005
Disposition:	DONE

Case Conditions

Below is a list of conditions for this permit case. Conditions typically record requirements that the applicant must meet to be in compliance with the permit.

Title:	pud monitoring
Wording:	AS PER WAC 246-272 AND JEFFERSON COUNTY CODE 8.15 ALL SYSTEMS REQUIRE MONITORING. THIS MONITORING IS PROVIDED BY AGREEMENT BETWEEN THE JEFFERSON COUNTY ENVIRONMENTAL HEALTH DIVISION AND THE JEFFERSON COUNTY PUBLIC UTILITY DISTRICT #1. THIS SEWAGE DISPOSAL SYSTEM WILL REQUIRE AN ACTIVE MONITORING CONTRACT WITH THE PUD #1 PRIOR TO FINAL APPROVAL OF THE SEWAGE DISPOSAL SYSTEM. While the County strongly recommends that the property owner allow inspectors to enter their property to inspect the system in order to insure that the system is functioning correctly, the property owner always has the right under the Fourth Amendment and our State Constitution, to refuse the inspectors access to their property. The property owner never loses the right to refuse access and can do so despite never having refused access before.
Title:	pressure test observation
Wording:	Health Dept. required to observe pressure test when system fully installed/complete, 48 hours

notice to be provided for scheduling.

Title: alternative-asbuilt required

Wording An asbuilt drawing and certification of completion by the designer is required prior to final approval.

Title: trench depth

Wording MAXIMUM TRENCH DEPTH 18 INCHES

Title: reserve area, alternative

Wording When/if designated reserve area is utilized an alternative system providing an additional level of treatment may be required.

Title: transport line double cased

Wording Any portion of transport line under a driven way is to be sleeved/cased or equivalent.

Title: no building permit guarantee

Wording Approval/issuance of a sewage disposal permit does not guarantee the approval of other development or a building permit on this site. Compliance with other Jefferson County and Washington State Codes is required.

Title: UDC compliance

Wording Approval of this sewage disposal permit does not preclude the permit holder from complying with the Unified Development Code for other/future development on the site.

Title: domestic strength waste

Wording This onsite sewage system is designed for domestic strength wastewater only. Disposal of any other waste strength is considered a violation of this permit.

Title: MONITORING SCHEDULE

Wording As per Jefferson County Code 8.15 all onsite sewage systems require monitoring. Monitoring shall be provided by an approved entity. THIS SYSTEM IS REQUIRED TO BE INSPECTED EVERY 3 YEARS.

Title: VIOLATION-limited permit life

Wording This permit was issued to correct a violation of WAC 246-272. The permit must be completed within 180 days of the date of issuance.

Title: VIOLATION-limited permit life

Wording This permit was issued to correct a violation of WAC 246-272. The permit must be completed within 180 days of the date of issuance.

Title:	SCREEN REQUIRED
Wording	A screen shall be provided either at the outlet of the septic tank or around the pump or at both locations. A pump shroud is required if only an outlet baffle filter is used.
Title:	O & M Manual required
Wording	Before final approval is given, the designer shall provide an operations and maintenance manual to the property owner. The manual must instruct the owner of the on site sewage system on the ways to properly operate and maintain all components of the system.
Title:	LOCATE TAPE
Wording	Locate tape or wire needs to be placed in all transport line trenches
Title:	ABANDON EXISTING 2 SYSTEMS
Wording	The existing systems at each of the club houses must both be abandoned prior to final approval of this permit
Title:	Stormwater BMPs
Wording	The project shall adhere to the Best Management Practices (BMPs) to control stormwater, erosion and sediment during construction. BMPs shall address permanent measures to stabilize soil exposed during construction, and in the design and operation of stormwater and drainage control systems.